

Emergency Rule 120-3-16-.0.10-.09

An additional sentence is hereby added to Rule 120-3-16-.09:

120-3-16-.09 Inspections.

Authorized representatives of the Safety Fire Division may conduct inspections of all facilities subject to this Chapter. Upon determination by such inspection that a liquefied petroleum gas system or any part thereof is unsafe to the extent that it endangers life or adjacent properties, the inspector may red tag the entire system or a specified portion thereof. The red tag may be removed only by an authorized representative of the Safety Fire Division. Any system or portion of a system that has been red tagged may no longer be used until the red tag has been removed. In the event of a consumer complaint, fire, or explosion of a vehicle or equipment covered under this Chapter, all owners, managers or operators of such vehicles or equipment shall make available, promptly and completely, all records regarding the delivery receipts, inspections, installations, leak tests, maintenance, service calls, pressure tests, and tank lease agreements, upon the request of the Safety Fire Division.

Authority O.C.G.A. Sections. 10-1-265, 25-2-4, 25-2-13, 25-2-16, 25-2-17, 25-10-5, 33-2-9, 50-13-21.