

**2003 International Fire Code®**  
**International Fire Code Council**

**308.3.1 Open-flame cooking devices.** Charcoal burners and other open-flame cooking devices shall not be operated on combustible balconies or within 10 feet (3048 mm) of combustible construction.

- Exceptions:**
1. One- and two-family dwellings.
  2. Where buildings, balconies and decks are protected by an automatic sprinkler system.

**308.3.1.1 Liquefied-petroleum-gas-fueled cooking devices.** LP-gas burners having an LP-gas container with a water capacity greater than 2.5 pounds [nominal 1 pound (0.454 kg) LP-gas capacity] shall not be located on combustible balconies or within 10 feet (3048 mm) of combustible construction.

- Exception:** One- and two-family dwellings.